

**ADDITIONS AGENDA FOR THE REGULAR MEETING OF  
THE COUNCIL OF THE TOWN OF ONOWAY  
HELD ON FRIDAY, FEBRUARY 18, 2022 IN THE COUNCIL CHAMBERS OF THE  
ONOWAY CIVIC CENTRE AND VIRTUALLY VIA ZOOM  
COMMENCING AT 9:30 A.M.  
MEETING IS BEING AUDIO/VIDEO RECORDED  
DUE TO PANDEMIC, PUBLIC PARTICIPATION IS ONLY AVAILABLE VIRTUALLY**

**7. ACTION ITEMS**

- Pg 1-37
- h) Darwell Lagoon Commission – Lac Ste. Anne County has made application for construction, operation and reclamation of the Darwell wastewater system under the Environmental Protection and Enhancement Act. The Commission is applying for approval to discharge a portion of their lagoon effluent to the Sturgeon River near Alberta Beach, anticipated to be once every three to five years. Anyone directly affected by this application can submit a written statement to Alberta Environment, and the deadline is February 24, 2022. Additional information from Lac Ste. Anne County about their application is attached.

*Recommendation:*

*direction as given by Council at meeting time*

- Pg 38-41
- i) Corporate Planning and Finance Course – Elected Officials Education Program (EOEP) – this is being offered over four evening sessions: February 16, February 23, March 2 and March 9. Some members of Council have indicated an interest in attending this virtual course taught by a municipal finance expert.

*Recommendation:*

*that the attendance of Councillors for the four sessions, beginning February 16, 2022 be ratified*

*or*

*some other direction as given by Council at meeting time*

# **PUBLIC NOTICE**

## **ENVIRONMENTAL PROTECTION AND ENHANCEMENT ACT**

### **NOTICE OF APPLICATION**

#### **LAC STE. ANNE COUNTY**

In accordance with the Environmental Protection and Enhancement Act (EPEA), Darwell Lagoon Commission has applied for an approval for the construction, operation and reclamation of the Darwell wastewater system. The existing Darwell wastewater lagoon is currently operating as an evaporative lagoon and is regulated under a Code of Practice Registration No. 590-02-00 (as amended). The wastewater system is located in the Hamlet of Darwell at NW 17-054-04-W5M.

With the changes proposed in this application, the Darwell lagoon will be regulated under an EPEA approval. The proposed changes include:

- construction of a regional wastewater lift station and septage receiving station at the existing Darwell lagoon system;
- a new pipeline (26.5 km, 200mm HOPE DR 11) to transfer wastewater effluent from the Darwell lagoon to the Sturgeon River near the Summer Village of Alberta Beach; and
- a wastewater outfall structure to discharge treated effluent to the Sturgeon River.

The Darwell Lagoon Commission is applying for approval to discharge a portion of their lagoon effluent to the Sturgeon River as part of this application. The frequency of lagoon discharge is anticipated to be once every three to five years.

A directly affected person may provide input into certain regulatory decisions, as allowed by the Environmental Protection and Enhancement Act (section 73). Specifically, any person who is directly affected by this application may submit a written statement of concern within 30 days of the date of this notice to:

**Environment and Parks Regulatory Approvals Center**  
5th Floor, South Petroleum Plaza  
9915 - 108 Street  
Edmonton, AB T5K 2G8  
Fax: 780.422.0154  
Email: [aep.epeaapplications@gov.ab.ca](mailto:aep.epeaapplications@gov.ab.ca)

The written statement of concern should include the following:

- the application number 008-590
- describe concerns that are relevant to matters regulated by the Environmental Protection and Enhancement Act
- explain how the filer of the concern will be directly affected by the activities proposed in the application
- provide the legal land location of the land owned or used by the filer where the concerns described are believed to be applicable
- state the distance between the land owned or used by the filer and the site in the application
- contact information including the full name and mailing address of the filer.
- Please provide a telephone number and/or email address for ease of contact.

Environment and Parks will review each written statement of concern, seek more information if needed, and notify each filer by letter of the decision to accept or reject their written submission as a valid statement of concern. The Public Notice of this application will also be posted on the Department's website at <https://aww.alberta.ca/PublicNoticesViewer.aspx>.

Statements of concern submitted regarding this application are public records which are accessible by the public and the applicant. Failure to file a statement of concern may affect the right to file a Notice of Appeal with the Environmental Appeals Board.

Copies of the application and additional information can be obtained from:

**Lac Ste. Anne County**  
Attention: Joe Duplessie  
56521 RGE RD 65  
Box 219  
Sangua, AB T0E 2A0  
Phone: 780.785.3411 (Ext. 260)  
Email: [jduplessie@LSAC.ca](mailto:jduplessie@LSAC.ca)

①



Stantec Consulting Ltd.  
1100-4900 50 Street, Red Deer AB T4N1X7

November 17, 2021  
File: 110170008

**Attention: Parmjit Roopral, Municipal Approvals Engineer**  
**Regulatory Approvals Centre**  
Alberta Environment and Parks  
Main Floor, Oxbridge Place  
9820 – 106 Street  
Edmonton, Alberta T5K 2J6

Dear Parmjit,

**Reference: Darwell Lagoon Commission – Darwell Regional Wastewater Transmission Line –  
Darwell Wastewater System Notification of Extension**

Please accept this letter on behalf of the Darwell Lagoon Commission for the above noted project. The project particulars for the Notification of Extension are as follows:

1. **Owner's Name:** Darwell Lagoon Commission.  
  
Contact Info: Joe Duplessie  
Phone: (780) 785-3411  
jduplessie@lsac.ca
2. **Project Name:** Darwell Regional Wastewater Transmission Line.
3. **Project Type:** Regional wastewater lift station, conveyance pipe, and new wastewater outfall.
4. **Project Description:** Construction of a regional wastewater lift station and septage receiving station located at the existing Darwell lagoon system, 26.5 km of 200mm HDPE DR 11 pipeline from Darwell to the Sturgeon River near the Summer Village of Alberta Beach, and a wastewater outfall structure to discharge treated effluent to the watercourse. This system is a temporary measure to alleviate AEP's concern of the Darwell lagoons overflowing during uncharacteristically high rainfall events and negatively impacting the environment. The construction of regional pipeline will ultimately become part of the Capital Region's long-term wastewater treatment system and the temporary outfall will be decommissioned. The Darwell Commission is applying for approval to discharge a small portion of their treated effluent storage volume to the Sturgeon River as part of this application. At which time discharge becomes necessary, the Darwell commission will conduct effluent sampling and receiving waterbody analysis to submit for AEP approval.
5. **Approval or Registration Number for Existing Facilities:**  
  
Registration Holder: Hamlet of Darwell, Wastewater System  
  
Registration No. 590-01-00



**Reference:** Darwell Lagoon Commission – Darwell Regional Wastewater Transmission Line – Darwell Wastewater System Notification of Extension

**6. Project Location**

Lift Station: NW 17-54-4-5

Pipeline: Hamlet of Darwell to the Sturgeon River

Wastewater Outfall: SE 36-54-3-5

- 7. Material Standards and Specifications:** The design utilizes the Standards and Specifications, which meet or exceed AWWA and/or CSA Standards.
- 8. Construction Schedule:** Construction for this project is anticipated from February 2022 to October 2022.
- 9. Confirmation:** I confirm that the installation of the wastewater main is within the flow design capacity of the wastewater collection systems, and that provisions are in place for the storage of excessive wet weather flows.

Enclosed are the preliminary engineered plans for the proposed wastewater line construction and the Code of Practice Notification for Extension of a Wastewater System.

Please contact us immediately if you have any questions.

Regards,

**Stantec Consulting Ltd.**

**Stephan Weninger, P.Eng.**  
Principal  
Phone: (403) 341-3320  
Fax: (403) 342-0969  
Stephan.Weninger@stantec.com

Stephan  
Lorne  
Weninger -- P.  
Eng. - APEGA

Digitally signed by  
Stephan Lorne  
Weninger -- P.  
Eng. - APEGA  
Date: 2021.11.19  
11:31:54 -07'00'

Attachment: Issued for Approval Design Drawings

c. Mike Yakemchuk -- Darwell Lagoon Commission  
Joe Duplessie -- Darwell Lagoon Commission

fs \\cd1044-f06\work\_group\1101\active\110170008\environmental\nov 17  
2021\et\_darwell\_wastewater\_lagoon\_epea\_registration\_notice\_of\_extension\_2021-nov-17.docx

## Application Form and Guide for an EPEA Registration Code of Practice for Wastewater Systems Using a Wastewater Lagoon

### Introduction

The attached form and guidelines outline the information required for an application for a registration for wastewater systems using a wastewater lagoon. The application has been prepared in accordance with the *Environmental Protection and Enhancement Act (EPEA) RSA 2000, cE-12*, the *Approvals and Registrations Procedure Regulation 113/1993*, and the *Wastewater and Storm Drainage Regulation 119/1993*. Please ensure that each section of the application is completed in a concise and clear manner.

Wastewater systems using a wastewater lagoon consists of one or more designed and constructed surface impoundments used for biological and physical treatment of wastewater, but does not include such a plant where it uses mechanical aeration. Wastewater lagoon systems also include sewers, valves, fittings, pumping / lift stations, and collection systems. For your information, the general steps and procedures that are followed when reviewing and issuing a Registration for a municipal wastewater lagoon is illustrated by the attached flow chart (Figure 1).

Application for a new Registration under the Code of Practice for systems using a wastewater lagoon must contain written confirmation, by a Professional Engineer, that all aspects of the wastewater lagoon design (including cell liner(s)) conform to the requirements of the Code of Practice, the Regulations under the Act, or a statement identifying and justifying any deviation. The plans and specifications submitted in support of the Code of Practice registration must also be signed and stamped by a Professional Engineer.


All information spaces in this application must be filled in or marked not applicable (N/A). Failure to provide all necessary information may cause the application to be rejected and returned to the applicant. All applications must be forwarded to:

Alberta Environment and Parks  
Regulatory Approvals Center  
5th Floor, South Petroleum Plaza  
9915 108 Street  
Edmonton, AB T5K 2G8  
Phone: 780-427-6311  
Fax: 780-422-0154  
E-mail: [aep.epeaapplications@gov.ab.ca](mailto:aep.epeaapplications@gov.ab.ca)

---

FOIP STATEMENT: Personal information on this form is collected under the authority of section 33(c) of the Freedom of Information and Protection of Privacy (FOIP) Act and will be used to administer the *Environmental Protection and Enhancement Act* and its associated regulations. This form is a public record that is available to anyone. All information contained on this form (including personal information) is disclosed by Alberta Environment and Parks to anyone requesting a copy in accordance with Section 2 of the *Environmental Protection and Enhancement Act*, Disclosure of Information Regulation. For further information about the collection and use of this information please contact Alberta Environment and Parks – Regulatory Approvals Centre at [aep.epeaapplications@gov.ab.ca](mailto:aep.epeaapplications@gov.ab.ca) or call 780-427-6311.

**FIGURE 1: THE PROCEDURE FOR A CODE OF PRACTICE REGISTRATION FOR WASTEWATER SYSTEMS USING A WASTEWATER LAGOON**



# Application Form and Guide for an EPEA Registration Code of Practice for Wastewater Systems Using a Wastewater Lagoon

## 1.0 Administrative Information

1.1 Name of the proposed wastewater lagoon system:

Darwell Wastewater System

1.2 Name and Address of wastewater lagoon system owner (Municipality / Commission / Utility / Water Co-op / Company):

Name: Darwell Lagoon Commission

Address: c/o Lac Ste Anne County - 56521 Rge Rd 65, Box 219 Sangundo, AB T0E 2A0

Contact Person: Joe Duplessie Position: Commission Manager

Telephone: (780) 785-3411 Fax: \_\_\_\_\_

Email Address: jduplessie@lsac.ca

Is your organization listed and in good standing on the Corporate Registry?

Yes  No

1.3 Legal land description of the existing or proposed wastewater lagoon system:

Land Location: NW SEC 17 TWP 54 RG 4 M 5

Land Location: \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location: \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location: \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

1.4 Submission of a map / plan of the area showing the location of the following landmarks must be submitted in support of the lagoon application. The map should show the following:

- (a) all sanitary lift stations;
- (b) the wastewater lagoon relative to the subdivision / Town / Village / Hamlet; (including a 300 meter setback circumference from the lagoon);
- (c) the overall specific cell layout of the lagoon, with cell types, and a flow diagram through the lagoon cells;
- (d) any and all flow meter(s) in the proposed lagoon system;
- (e) any disinfection and or dechlorination facility (if applicable); N/A

- (f) any and all treated effluent pump stations (if applicable);
- (g) any and all agricultural fields, golf courses or parks that will receive wastewater through wastewater irrigation (if applicable); N/A
- (h) the treated effluent outfall from the final storage cell (if applicable); and
- (i) the wastewater collection piping in the present or proposed treated wastewater collection system for the development that are or will be part of the lagoon system. N/A

1.5 Have setbacks under the *Municipal Government Act* and / or the *Environmental Protection and Enhancement Act* been applied for and issued by the local Subdivision Approving Authority relative to this existing or proposed wastewater lagoon system?

Yes  No

If Yes to Section 1.5, then please provide copies of all setbacks variances that have been issued for this wastewater system:

Setback Waiver #1: Issued N/A

Setback Waiver #2: Issued \_\_\_\_\_

Setback Waiver #3: Issued \_\_\_\_\_

1.6 If Yes to Section 1.5, then please provide a map detailing the location of all properties and corresponding legal land locations relating to the setback variances that have been issued relative to this wastewater system.

1.7 Operating staff and person(s) that will be responsible for the day to day operation of the lagoon system:

**Lagoon Treatment**

NAME OF OPERATOR(S)	POSITION	AEW CERTIFICATION		WORK PHONE #
		CERT. #	CLASS	
Joe Dupessie	Commission Manager / Utilities Manager	2864	I	(780) 785-3411

1.8 Operating staff and person(s) that will be responsible for the day to day operation of the lagoon wastewater collection system:

**Wastewater Collection**

NAME OF OPERATOR(S)	POSITION	AEW CERTIFICATION		WORK PHONE #
		CERT. #	CLASS	
Joe Dupessie	Commission Manager / Utilities Manager	2864	I	(780) 785-3411
*All wastewater is delivered to the Darwell lagoons by haulers. Haulers are managed by Joe Duplessie.				



## 2.0 Wastewater System (Technical Data)

- 2.1 Present or projected population served by the wastewater lagoon system: 3,481 Due to the seasonal nature of the population served by the Darwell Wastewater System, wastewater generation is proven lower than standard private wastewater design guidelines
- 2.2 Projected life of the wastewater treatment plant: 25 Years
- 2.3 Projected population at end of life for the wastewater lagoon system: 4,928
- 2.4 Are there any other Municipality(ies), Development(s) Commissions / Co-ops / or Companies outside the municipal boundaries that discharge raw or partially treated wastewater into the wastewater collection system (other than septic truck haul)?  
 Yes  No

If Yes, please provide a list of the systems, the name and phone number of the contact person(s) and approximate annual flows or population.

NAME OF SYSTEM	CONTACT PERSON	PHONE NUMBER	ANNUAL FLOW (M <sup>3</sup> ) OR POPULATION
N/A			

- 2.5 Does your wastewater lagoon system receive septic tank waste? Yes  No

If Yes, please detail the septage management plan: (including septage hauler agreements, annual volume of septage, conditions of wastewater facility use, limitation of access, surveillance, sampling):

The Darwell wastewater system currently accepts septic tank waste from approved haulers around Darwell and the greater portion of Isle Lake. Historically, haulers have paid on a per load basis and wastewater was not metered or sampled. However, a temporary Septage Receiving Station Unit was placed to gather data for the purpose of projecting wastewater volumes. This unit, equipped with a pH probe and chemical sampling, is intended to be installed permanently to alleviate limitations in sampling, billing, and flow monitoring. The anticipated accepted annual flow from haulers is 45,000m<sup>3</sup>

If No, please detail the concerns or circumstances that preclude septage from being received:

N/A

---



---




---



---

Is the septic waste metered? Yes  No  Average monthly flows (m<sup>3</sup>) 3,750 (125m<sup>3</sup>/day)

- 2.6 Submission of engineering drawings and specifications for the wastewater lagoon (including cell capacities) (signed and stamped by a Professional Engineer) of the proposed wastewater lagoon system. Yes



2.7 Submission of engineering drawings and specification including piping profiles and design capacity (signed and stamped by a Professional Engineer) of the proposed wastewater collection system. Yes

2.8 All aspects of the design of the wastewater collection systems complies with the design requirements of:

(a) this Code of Practice; and

(b) the regulations under the Act.

Yes  No

If No, identification and justification of the deviation from this Code of Practice and/or the regulations under the Act: (with Engineer's signature and stamp)

The Darwell wastewater system does not currently include anaerobic lagoon treatment. The current daily flow volume accepted into the Darwell Wastewater System is under 250m<sup>3</sup> per day and does not require anaerobic cells. At the 25-year design horizon of the wastewater system, the flows accepted are not expected to exceed 250m<sup>3</sup> per day also precluding the requirement of anaerobic cells onsite.

If Yes, *Environmental Protection and Enhancement Act* Project sign-off sheet must be signed, stamped and included at the end of this application form.

### 3.0 Raw Wastewater Collection System

3.1 Are there sanitary sewer use bylaw(s) in place to ensure the integrity of the wastewater treatment process? Yes  No

3.2 Do the sanitary sewer use bylaw(s) either preclude discharge of some waste(s) or require pre-treatment for industrial or non-compatible waste? Yes  No

If No, please explain:

---



---



---



---

3.3 Raw Wastewater Pumping Stations (lift stations):

LIFT STATION NUMBER AND LOCATION	EMERGENCY OVERFLOW / DISCHARGE ROUTE	POWER RATING (KW)	CAPACITY (L/S)
N/A			
*All wastewater is delivered to the Darwell Wastewater System by haulers, hence there are no raw water collection lift stations connected to the Darwell wastewater system.			

## WASTEWATER LAGOON REQUIREMENTS

Average Daily Design Flow (m <sup>3</sup> /day)	Number of Anaerobic Cells (2 day retention/cell)	Requirement for Facultative Cell(s) (60 day retention/cell)	Requirement for 12 Month Storage Cell(s) (average daily design flow)
< 250	0	Yes maximum depth 1.5 meters	Yes maximum depth 3.0 meters
250 to ≤ 500	2 in series minimum depth 3.0 meters	Yes, maximum depth 1.5 meters	Yes, maximum depth 3.0 meters
> 500	4 in series minimum depth 3.0 meters	Yes, maximum depth 1.5 meters	Yes, maximum depth 3.0 meters

**3.4 Lagoon system description and capacities:**

**Proposed Wastewater Lagoon System**

Receiving - 125 m<sup>3</sup>/day average currently  
 Planned - 175 m<sup>3</sup>/day average to be received at 25-year design horizon

Proposed or existing Average Daily Flow (m<sup>3</sup> / day): \_\_\_\_\_

Anaerobic cells – number of cells: \_\_\_\_\_, volume / cell (m<sup>3</sup>): \_\_\_\_\_

Facultative cells – number of cells: 2, volume / cell (m<sup>3</sup>): total 94,000

Final storage cell – number of cells: 1, volume / cell (m<sup>3</sup>): 278,575

**3.5 Are there any septage dump stations? Yes  No**

If Yes, how many 1 locations Within the Darwell Wastewater System, directly entering the receiving Cell

Are the septage dump stations metered? Yes  No  However, it is proposed to meter all wastewater entering the facility.  
 Average monthly flows (m<sup>3</sup>) 3,750

**3.6 Wastewater system metering:**

Wastewater flow monitoring location(s): Darwell lagoons

**3.7 Wastewater pumping: Yes  No**

UNIT	POWER RATING (KW)	CAPACITY (L/S)
Duplex Pumping System	54 KW	21 L/s

Total pumping capacity 21 L/s (L/s).

Description and location of fuel source for pumping: Fortis 3PH Power, with Distribution connection from Township Road 542.

3.8 Inventory of all water treatment chemicals used. (Please identify all the chemicals used seasonally or continuously, including pH adjusters, oxidants or disinfectants).

CHEMICAL NAME	NSF APPROVED Y/N	CHEMICAL TYPE	POINT OF INJECTION	SEASONAL / CONTINUOUS
N/A				

#### 4.0 Treated Effluent Discharge

4.1 Treated effluent discharge method:

(a) Batch discharge to watercourse or water body:

Description, volume and location of the treated effluent storage:

The Darwell Wastewater System has a single storage cell with a volume of 278,575m3, which is the third cell in series in the treatment facility. Since the volume of wastewater received by the facility is currently 45,000 m3/year, annual discharges will not be required. Discharges can be timed and volume adjusted to the requirements of the receiving stream.

Land Location   NW   SEC   17   TWP   54   RG   4   M   5  

or other (i.e.: street address) \_\_\_\_\_

GPS Co-ordinates: Latitude:   53.667030   Longitude:   -114.5572717  

Description and location of the treated effluent outfall:

Overland type outfall to the bank of the Sturgeon River, east of Alberta Beach.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Land Location   SW   SEC   25   TWP   54   RG   3   M   5  

or other (i.e.: street address) \_\_\_\_\_

GPS Co-ordinates: Latitude:   53.702247   Longitude:   -114.296643  



Description of the existing or proposed discharge times and durations from the treated effluent storage:

The discharge period will occur in spring or fall over a maximum three week period, or until the maximum loading limit assigned to the receiving Sturgeon River Waterbody is reached. It is anticipated that the Darwell wastewater system will require discharge from storage once every 3-5 years, at which time effluent and receiving waterbody reporting will be submitted. The anticipated maximum batch treated effluent discharge will be 38,000 m<sup>3</sup> at a rate of 21 L/s or 1,814m<sup>3</sup>/day. At the time of discharge, the Commission will coordinate the offset of discharge timing with TriVillage Regional Sewage Commission to ensure overlap does not occur.

Description and determination of adequate outlet regarding the discharge route:  
Immediate:

Termination of the wastewater outfall line will be to an overland type outlet, complete with concrete dispersion headwall to rip-rap on the Sturgeon River bank.

Ultimately to:

The Sturgeon River

Have easement(s) been obtained for the discharge route? Yes  No

If No please explain:

Any required easements will be obtained at the final confirmation of environmental approval.

Description, volume and location of the treated effluent storage:

The Darwell Wastewater System has a single storage cell with a volume of 278,575m<sup>3</sup>, which is the third cell in series in the treatment facility. Any discharge will be monitored for quality and quantity meeting acceptable limits for the receiving stream.

Land Location   NW   SEC   17   TWP   54   RG   4   M   5  

or other (i.e.: street address) \_\_\_\_\_

GPS Co-ordinates: Latitude:   53.667030   Longitude:   -114.5572717  

(b) ~~Wastewater irrigation~~

Type of the irrigation system:

Permanent in-ground

Hand move

Wheel move

Pivot

Other:  \_\_\_\_\_

Topographical description of the irrigated land(s):

---

---

---

---

Total land area irrigated: \_\_\_\_\_ hectares

Land Locations of the irrigated land(s):

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

Land irrigability study (as per EPEA Guidelines for Municipal Wastewater Irrigation) must be submitted for irrigated lands in support of this application:

Date of study completion: \_\_\_\_\_

Existing or Projected wastewater irrigation application volume (annual total):  
\_\_\_\_\_ mm (total).

Existing or Projected wastewater irrigation application rate:  
\_\_\_\_\_ mm/hr or mm/irrig. event

(c) Continuous or batch discharge to landlocked wetland.

Description, approximately area (hectares) and location of the wetland:

---

---

---

---

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

(d) Continuous or batch discharge to a wetland with subsequent discharge to a watercourse or water body.

Type of wetland: Natural  Man Made/designed  Hybrid

Purpose of wetland:

Wastewater treatment (recognized part of treatment train)   
Wastewater Polishing   
Additional Wastewater storage   
Other:  \_\_\_\_\_

Wetland Management Plans in place: Yes  No

Volume and water level management   
Aquatic plant management   
Phosphorus management

Description, volume and location of the treated effluent storage:  
(pre-wetland - if applicable)

---

---

---

---

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

Description, approximately area (hectares<sup>2</sup>) and location of the wetland:

---

---

---

---

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

Description and location of the treated effluent outfall to watercourse from wetland:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Land Location \_\_\_\_\_ SEC \_\_\_\_\_ TWP \_\_\_\_\_ RG \_\_\_\_\_ M \_\_\_\_\_

GPS Co-ordinates: Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

## 5.0 Groundwater Monitoring Program

5.1 Groundwater wells: (around lagoon site)

Number of groundwater wells: 7 distributed around the Darwell Wastewater System lagoon site

Well No.	Legal Land Location
	GPS Co-ordinates
Wells No.: 02-02, 02-04, 02-05, 02-06 02-07, 03-02, and 08-03	NW 17-54-4-W5M

5.2 Confirmation that water samples will be taken and analyzed from groundwater wells prior to putting lagoon into operation: Yes

5.3 Confirmation that water samples will be taken and analyzed from groundwater wells three (3) times, three months apart during the first year of operation: Yes  Wells are existing for the Darwell Wastewater System. Sampling will be maintained annually.

5.4 Groundwater Analyses / monitoring (prior to lagoon start-up and during first year of operation):

Parameters	Monitoring Frequency (in each groundwater well)
pH	Once before operational, 3 times, 3 months apart during first year
Electrical Conductivity	
Calcium	
Magnesium	
Total Hardness	
Sodium	
Potassium	
Iron	
Total Phosphorus	
Nitrate-Nitrogen	



Parameters	Monitoring Frequency (in each groundwater well)
Nitrite-Nitrogen	Once before operational, 3 times, 3 months apart during first year
Ammonia-Nitrogen	
Chloride	
Fluoride	
Sulphate	
Carbonate	
Bicarbonate	
Total Alkalinity	
Total Dissolved Solids (TDS)	
Total Kjeldahl Nitrogen	
Chemical Oxygen Demand	
Depth to groundwater level	

5.5 Groundwater Analyses / monitoring (after first year and for subsequent years of operation):

Parameters	Monitoring Frequency (in each groundwater well)
Depth to groundwater level	Immediately before lagoon discharge
	Immediately after lagoon discharge is complete
	Approximately one month after lagoon discharge(s)

## 6.0 Treated Effluent Limits and Monitoring

6.1 Lagoon Discharge – Monitoring

### Direct Discharge - Monitoring

Parameters	Sample Type	Sampling Location	Minimum Monitoring Frequency
Carbonaceous Biochemical Oxygen Demand (CBOD)	Grab	Point at which treated wastewater is discharged from the wastewater lagoon	Once during discharge, after the first day of discharge
Total Suspended Solids (TSS)			

6.2 Wastewater Irrigation - Limits

### Wastewater Irrigation - Treated Wastewater Limits

Parameter	Limit
Carbonaceous Biochemical Oxygen Demand (CBOD)	< 100 mg/L
Chemical Oxygen Demand (COD)	< 150 mg/L
Total Suspended Solids (TSS)	< 100 mg/L

Parameter	Limit
Electrical Conductivity (EC)	< 2.5 dS/m
Sodium Absorption Ratio (SAR)	< 9 (*SAR greater than 9 is unacceptable) *consult WW irrigation guidelines for corresponding unrestricted and restricted SAR values
pH	6.5 to 8.5

### 6.3 Wastewater Irrigation – Monitoring

#### Wastewater Irrigation - Treated Wastewater Monitoring

TREATED WASTEWATER USED FOR IRRIGATION FOR EACH IRRIGATION SITE			
Parameters	Minimum Monitoring Frequency	Sample Type	Sample Location
Carbonaceous Biochemical Oxygen Demand (CBOD)	One sample each: (a) prior to each irrigation application season, and (b) at the mid point of each irrigation season	Grab	At the treated wastewater irrigation intake point
Chemical Oxygen Demand (COD)			
Total Suspended Solids (TSS)			
Electrical Conductivity (EC)			
Sodium Absorption Ratio (SAR)			
pH			

#### Additional Wastewater Irrigation Treated Wastewater Limits for Golf Course and Park Irrigation

Parameter	Limit
Total coliform counts	< 1000 per 100 ml, based on the monthly geometric mean
Fecal coliform counts	< 200 per 100 ml, based on the monthly geometric mean
Total Chlorine Residual	< 2.0 mg/L, based on the monthly arithmetic mean of daily grab samples

## 7.0 Wastewater Application Signature (Owner)

- 7.1 The *Environmental Protection and Enhancement Act* and Regulations, provide a specific definition for the "owner" and "person responsible for a wastewater system". Therefore, the person(s) responsible/person signing this document should be familiar with the applicable sections of the *Environmental Protection and Enhancement Act* and the Regulations.

The sections of the *Environmental Protection and Enhancement Act* and Regulations that are of particular relevance to wastewater systems are:

- (a) *Environmental Protection and Enhancement Act (EPEA) RSA 2000, cE-12;*
- (b) *Activities Designation Regulation 276/2003;*
- (c) *Approvals and Registrations Procedure Regulation 113/1993;*
- (d) *Wastewater and Storm Drainage Regulation 119/1993;*
- (e) *Code of Practice for Wastewater Systems Using a Wastewater Lagoon September 2003.*

I certify that I am familiar with the information contained in this application, and that to the best of my knowledge and belief, such information is true, complete and accurate.

Joe Duplessie  
Printed Name of Person Signing

56521 Range Road 65, Box 219  
Corporate Address

(780) 785-3411  
Corporate Telephone Number

November 17, 2021  
Date of Application

Commission Manager  
Title

T0E 2A0  
Corporate Postal Code

Corporate Fax Number

  
Signature

# EPEA Code of Practice for Wastewater Systems Using a Wastewater Lagoon

**Project Name/Type** Darwell Regional Wastewater Transmission Line

**Location** NW 17-54-4-5 to SW25-54-3-5


**Municipality** Lac Ste Anne County

I acknowledge that I have reviewed the *Standards and Guidelines for Municipal Wastewater, Wastewater, and Storm Drainage Systems*, January 2006, and the Code of Practice for Wastewater Systems Using a Wastewater Lagoon, and certify that the design of the above noted project complies with all of the design requirements noted specified.

SIGNED AND STAMPED by a professional engineer.

NAME  
COMPANY

Submissions that are found to not be in accordance with the Standards and Guidelines may result in enforcement action and/or referral to APEGGA.  
For projects that do not comply with all of the Standards and Guidelines please submit a detailed explanation of the deficiency and why it is necessary.



Environmental Management  
Central Region

Suite #1, 250 Diamond Ave  
Spruce Grove, Alberta  
Canada T7X 4C7

Telephone: (780) 960-8600  
Fax: (780) 960-8605

May 1, 2007

File No. 005 - 590

Len Szybunka, County Manager  
Lac Ste Anne County  
PO Box 219  
Sangudo, AB T0E 2A0

**RE: Registration Holder: Hamlet of Darwell, Wastewater System,  
Registration 590-02-00 Application No. 005-590  
Notice - Code of Practice for Wastewater Systems Using a Wastewater Lagoon**


The Darwell wastewater system operated by the Lac Ste Anne County is currently operating under a registration under the *Environmental Protection and Enhancement Act*, and required to follow the requirements of the latest approval No. 590-01-00, as amended, issued for the facility.

In accordance with section 3.2(2) of the *Wastewater and Storm Drainage Regulation*, the Director is providing notice that the *Code of Practice for Wastewater Systems Using a Wastewater Lagoon*, as amended or replaced from time to time, will now be applied to the operation of the Darwell wastewater system.

Pursuant to section 3.2(3) of the *Wastewater and Storm Drainage Regulation*, all of the Code of Practice applies effective May 1, 2007.

If you have any questions regarding this Notice, please contact David Dowhaniuk at (780) 960-8626.


Sincerely,



Tom Slater, P.Eng.  
District Approvals Manager  
Designated Director under the Act

cc: Regulatory Approvals Centre  
David Dowhaniuk, Spruce Grove





DATE	ENG.	BY	SUBJECT
REVISIONS			

**RECORD DRAWING**

AS CONSTRUCTED DIMENSIONS, MEASUREMENTS AND OTHER DETAILS CONTAINED IN THIS RECORD DRAWING HAVE BEEN OBTAINED BY ASSOCIATED ENGINEERING SUBJECTS LTD (AESL) FROM VARIOUS SOURCES. SUCH INFORMATION REPRESENTS THE BEST INFORMATION AVAILABLE TO AESL AT THE TIME OF PREPARATION OF THIS RECORD DRAWING. AESL DOES NOT IN ANY WAY WARRANT THAT SUCH INFORMATION IS ACCURATE AND ASSUMES NO RESPONSIBILITY FOR ANY ERRORS OR OMISSIONS CONTAINED THEREIN.



PROJECT No.	2008348
SCALE	AS SHOWN
DRAWN	B. Wong
DESIGNED	R. Thompson
CHECKED	J. Fetter
APPROVED	
DATE	2008-05
	INITIAL

LAC STE ANNE COUNTY  
DARWELL LAGOON COMMISSION

2008 DARWELL LAGOON EXPANSION		
DRAWING NUMBER	REV. NO.	SHEET
3545-1-103	2	1

SERVICE REQUESTED (3PM Cut off)			REPORT CONTACT		INVOICE CONTACT		PROJECT DETAILS	
<b>Service</b> Regular <input checked="" type="checkbox"/> <b>Surcharge</b> None <input type="checkbox"/> <b>TAT</b> *Business days 4 days <input type="checkbox"/> <hr/> <b>RUSH TAT (3PM Cut off)</b> Rush 50% 2-3 days <input type="checkbox"/> Priority 100% Next day <input type="checkbox"/> Emergency 200% Weekend/Holiday Same day <input type="checkbox"/> Report Date: <u>01-04-21</u>	Company: <u>LAC STE ANNE COUNTY</u> Contact: <u>KYLE SNAJCHUK</u> Emails: <u>KSNACHUK@LSAC.CA</u> <u>J.DUPLESSIE@LSAC.CA</u> Address: <u>Box 219 SANGUINAR AB</u> <u>TOE 2A0</u> Phone: <u>780-284-8221</u>		Same as Report <input checked="" type="checkbox"/> Company: _____ Contact: _____ Email: _____ Address: _____ Phone: _____		Project ID: <u>Well Sample</u> Location ID: <u>DARWELL LAGOON</u> P.O.: _____ Quotation #: _____			

Guideline				Client			ANALYSIS REQUESTED														
<input type="checkbox"/> AB Tier 1 <input type="checkbox"/> BC <input type="checkbox"/> CCME <input type="checkbox"/> MB <input type="checkbox"/> SPIGEC <input type="checkbox"/> Drinking Water <input type="checkbox"/> D50 <input type="checkbox"/> Other _____				Rel. by: <u>V/S</u> Date: <u>Sept 27/21</u> Time: <u>1:50pm</u>	Rec. by: <u>[Signature]</u> Date: <u>01-04-21</u> Time: <u>6:50</u>	Rec. by: <u>EW/JP</u> Date: <u>28 Sept 21</u> Time: <u>8:50am</u>	Additional Notes: _____ LAB USE ONLY Temp: <u>13.0°C</u>			POTASSIUM    TOTAL METALS    NH3-N/TKN HOLD ANALYSIS    SPECIAL INSTRUCTIONS											
LAB ID	SAMPLE IDENTIFICATION	DEPTH	DATE SAMPLED (DD/MM/YYYY)	TIME SAMPLED	MATRIX (SOIL / WATER)																
	<del>02-02</del>	<del>1.8m</del>	<del>27/09/21</del>	<del>11:20am</del>	<del>WATER</del>																
1	02-04	1.8m	"	11:20am	"	✓	✓	✓													
2	02-05	0m	"	11:30am	"	✓	✓	✓													
3	02-06	1.3m	"	11:36am	"	✓	✓	✓													
4	02-07	3.4m	"	11:43am	"	✓	✓	✓													
	<del>02-01</del>																				
5	03-02	4.8m	"	12:03pm	"	✓	✓	✓													
	<del>03-03</del>																				
6	THOB-03	2.2m	"	11:57AM	"	✓	✓	✓													
7	02-02	2.3m	"	12:57AM	"	✓	✓	✓													

Fill out chain of custody completely to avoid processing delays. Gray fields are for lab use only.

23



### ANALYTICAL REPORT

**Client:** Lac Ste. Anne County  
 Box 219  
 Sangudo, AB, T0E 2A0

**Attention:** Joe Duplessie - Lac Ste Anne Count

<b>KaizenLAB JOB #:</b>	317767
<b>DATE RECEIVED:</b>	28-Sep-2021
<b>DATE REPORTED:</b>	01-Oct-2021
<b>PROJECT ID:</b>	Well Sample
<b>LOCATION:</b>	Darwell Lagoon

**KaizenLAB Sample #:** 317767\_001    **Sample ID:** 02-04  
**Date Sampled:** 11:20 27-Sep-2021

Parameter Description	Units	Result	Guideline Limits*	Comment
<b>Routine Water Potability Analysis (Potability pkg #2)</b>				
Electrical Conductivity (EC)	uS/cm	2160		
pH		7.5	7.0-10.5 (AO)	Acceptable
Total Dissolved Solids (calculated)	mg/L	1354	500 (AO)	Unacceptable
True Colour	TCU	<4	15 (AO)	Acceptable
Turbidity	NTU	2.16	0.1/0.3/1.0 <sup>see notes</sup>	See notes
<b>Alkalinity Parameters of Water</b>				
Alkalinity (phenolphthalein, as CaCO3)	mg/L	<2.0		
Alkalinity (total, as CaCO3)	mg/L	953.0		
Bicarbonate (as HCO3)	mg/L	1162		
Carbonate (as CO3)	mg/L	<1.5		
Hydroxide (as OH)	mg/L	<0.5		
<b>Anions in Water by IC</b>				
Bromide	mg/L	0.22		
Chloride	mg/L	174.1	250 (AO)	Acceptable
Fluoride	mg/L	0.22	1.5 (MAC)	Pass
Nitrate-N	mg/L	<0.010	10 (MAC)	Pass
Nitrite-N	mg/L	<0.005	1 (MAC)	Pass
Nitrite-N + Nitrate-N	mg/L	<0.015		
Phosphate	mg/L	<0.10		
Sulphate	mg/L	115.4	500 (AO)	Acceptable
<b>Cations in Water by ICP-OES</b>				
Dissolved Calcium	mg/L	296.7		
Dissolved Iron	mg/L	<0.05	0.3 (AO)	Acceptable

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

24

Unit# 288, 2880 45 Ave S.E.  
 Calgary, AB, T2B 3M1  
 Phone (403) 297-0868  
 Fax: (403) 297-0869  
 e-Mail: kaizenlab@kaizenlab.ca



KaizenLAB Sample #: 317767\_001    Sample ID: 02-04  
 Date Sampled: 11:20 27-Sep-2021

Parameter Description	Units	Result	Guideline Limits*	Comment
Dissolved Magnesium	mg/L	75.1		
Dissolved Manganese	mg/L	<0.05		
Dissolved Potassium	mg/L	7.5		
Dissolved Sodium	mg/L	103.4	200 (AO)	Acceptable
Hardness (calculated, as CaCO3)	mg/L	1050		
Sodium Adsorption Ratio		1.39		
<b>Ammonia In water</b>				
Ammonia-N	mg/L	<0.05		
Total Kjeldahl Nitrogen	mg/L	<2.00		
Total Phosphorus	mg/L	<0.040		

**Notes:**

- Turbidity: Based on slow sand or diatomaceous earth filtration (1.0 NTU) / membrane filtration (0.1 NTU) / conventional treatment (0.3 NTU). No limits apply for well water not under the influence of surface water. For further details and additional guidance restriction, see Guidelines for Canadian Drinking Water Quality (GCDWQ 2019).

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

25

Unit# 288, 2880 45 Ave S.E.  
 Calgary, AB, T2B 3M1  
 Phone (403) 297-0868  
 Fax: (403) 297-0869  
 e-Mail: kaizenlab@kaizenlab.ca



KaizenLAB Sample #: 317767\_002 Sample ID: 02-05  
 Date Sampled: 11:30 27-Sep-2021

Parameter Description	Units	Result	Guideline Limits*	Comment
<b>Routine Water Potability Analysis (Potability pkg #2)</b>				
Electrical Conductivity (EC)	uS/cm	1630		
pH		7.7	7.0-10.5 (AO)	Acceptable
Total Dissolved Solids (calculated)	mg/L	940	500 (AO)	Unacceptable
True Colour	TCU	<4	15 (AO)	Acceptable
Turbidity	NTU	5.11	0.1/0.3/1.0 <sup>see notes</sup>	See notes
<b>Alkalinity Parameters of Water</b>				
Alkalinity (phenolphthalein, as CaCO <sub>3</sub> )	mg/L	<2.0		
Alkalinity (total, as CaCO <sub>3</sub> )	mg/L	713.4		
Bicarbonate (as HCO <sub>3</sub> )	mg/L	869.8		
Carbonate (as CO <sub>3</sub> )	mg/L	<1.5		
Hydroxide (as OH)	mg/L	<0.5		
<b>Anions in Water by IC</b>				
Bromide	mg/L	0.17		
Chloride	mg/L	142.0	250 (AO)	Acceptable
Fluoride	mg/L	0.30	1.5 (MAC)	Pass
Nitrate-N	mg/L	<0.010	10 (MAC)	Pass
Nitrite-N	mg/L	<0.005	1 (MAC)	Pass
Nitrite-N + Nitrate-N	mg/L	<0.015		
Phosphate	mg/L	<0.10		
Sulphate	mg/L	29.30	500 (AO)	Acceptable
<b>Cations in Water by ICP-OES</b>				
Dissolved Calcium	mg/L	178.4		
Dissolved Iron	mg/L	<0.05	0.3 (AO)	Acceptable
Dissolved Magnesium	mg/L	48.2		
Dissolved Manganese	mg/L	<0.05		
Dissolved Potassium	mg/L	7.3		
Dissolved Sodium	mg/L	99.0	200 (AO)	Acceptable
Hardness (calculated, as CaCO <sub>3</sub> )	mg/L	644.0		
Sodium Adsorption Ratio		1.70		
<b>Ammonia in water</b>				
Ammonia-N	mg/L	0.10		
Total Kjeldahl Nitrogen	mg/L	<2.00		
Total Phosphorus	mg/L	0.047		

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

26

Unit# 288, 2880 45 Ave S.E.  
Calgary, AB, T2B 3M1  
Phone (403) 297-0868  
Fax: (403) 297-0869  
e-Mail: kaizenlab@kaizenlab.ca



**Notes:**

- Turbidity: Based on slow sand or diatomaceous earth filtration (1.0 NTU) / membrane filtration (0.1 NTU) / conventional treatment (0.3 NTU). No limits apply for well water not under the influence of surface water. For further details and additional guidance restriction, see Guidelines for Canadian Drinking Water Quality (GCDWQ 2019).

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

27

KaizenLAB Sample #: 317767\_003    Sample ID: 02-06  
 Date Sampled: 11:36 27-Sep-2021

Parameter Description	Units	Result	Guideline Limits*	Comment
<b>Routine Water Potability Analysis (Potability pkg #2)</b>				
Electrical Conductivity (EC)	uS/cm	1550		
pH		7.7	7.0-10.5 (AO)	Acceptable
Total Dissolved Solids (calculated)	mg/L	1046	500 (AO)	Unacceptable
True Colour	TCU	<4	15 (AO)	Acceptable
Turbidity	NTU	1.48	0.1/0.3/1.0 <sup>see notes</sup>	See notes
<b>Alkalinity Parameters of Water</b>				
Alkalinity (phenolphthalein, as CaCO <sub>3</sub> )	mg/L	<2.0		
Alkalinity (total, as CaCO <sub>3</sub> )	mg/L	672.8		
Bicarbonate (as HCO <sub>3</sub> )	mg/L	820.3		
Carbonate (as CO <sub>3</sub> )	mg/L	<1.5		
Hydroxide (as OH)	mg/L	<0.5		
<b>Anions In Water by IC</b>				
Bromide	mg/L	0.12		
Chloride	mg/L	3.23	250 (AO)	Acceptable
Fluoride	mg/L	0.43	1.5 (MAC)	Pass
Nitrate-N	mg/L	<0.010	10 (MAC)	Pass
Nitrite-N	mg/L	<0.005	1 (MAC)	Pass
Nitrite-N + Nitrate-N	mg/L	<0.015		
Phosphate	mg/L	<0.10		
Sulphate	mg/L	306.5	500 (AO)	Acceptable
<b>Cations In Water by ICP-OES</b>				
Dissolved Calcium	mg/L	213.8		
Dissolved Iron	mg/L	<0.05	0.3 (AO)	Acceptable
Dissolved Magnesium	mg/L	66.9		
Dissolved Manganese	mg/L	<0.05		
Dissolved Potassium	mg/L	6.3		
Dissolved Sodium	mg/L	38.6	200 (AO)	Acceptable
Hardness (calculated, as CaCO <sub>3</sub> )	mg/L	809.4		
Sodium Adsorption Ratio		0.59		
<b>Ammonia in water</b>				
Ammonia-N	mg/L	<0.05		
Total Kjeldahl Nitrogen	mg/L	<2.00		
Total Phosphorus	mg/L	<0.040		

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020: MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

Unit# 288, 2880 45 Ave S.E.  
Calgary, AB, T2B 3M1  
Phone (403) 297-0868  
Fax: (403) 297-0869  
e-Mail: kaizenlab@kaizenlab.ca



**Notes:**

- Turbidity: Based on slow sand or diatomaceous earth filtration (1.0 NTU) / membrane filtration (0.1 NTU) / conventional treatment (0.3 NTU). No limits apply for well water not under the influence of surface water. For further details and additional guidance restriction, see Guidelines for Canadian Drinking Water Quality (GCDWQ 2019).

(29)

Unit# 288, 2880 45 Ave S.E.  
 Calgary, AB, T2B 3M1  
 Phone (403) 297-0868  
 Fax: (403) 297-0869  
 e-Mail: kaizenlab@kaizenlab.ca



KaizenLAB Sample #: 317767\_004 Sample ID: 02-07  
 Date Sampled: 11:43 27-Sep-2021

Parameter Description	Units	Result	Guideline Limits*	Comment
<b>Routine Water Potability Analysis (Potability pkg #2)</b>				
Electrical Conductivity (EC)	uS/cm	2550		
pH		7.6	7.0-10.5 (AO)	Acceptable
Total Dissolved Solids (calculated)	mg/L	2173	500 (AO)	Unacceptable
True Colour	TCU	<4	15 (AO)	Acceptable
Turbidity	NTU	25.1	0.1/0.3/1.0 <sup>see notes</sup>	See notes
<b>Alkalinity Parameters of Water</b>				
Alkalinity (phenolphthalein, as CaCO3)	mg/L	<2.0		
Alkalinity (total, as CaCO3)	mg/L	541.5		
Bicarbonate (as HCO3)	mg/L	660.3		
Carbonate (as CO3)	mg/L	<1.5		
Hydroxide (as OH)	mg/L	<0.5		
<b>Anions in Water by IC</b>				
Bromide	mg/L	0.1		
Chloride	mg/L	59.67	250 (AO)	Acceptable
Fluoride	mg/L	0.21	1.5 (MAC)	Pass
Nitrate-N	mg/L	0.044	10 (MAC)	Pass
Nitrite-N	mg/L	<0.005	1 (MAC)	Pass
Nitrite-N + Nitrate-N	mg/L	0.044		
Phosphate	mg/L	<0.10		
Sulphate	mg/L	1145	500 (AO)	Unacceptable
<b>Cations in Water by ICP-OES</b>				
Dissolved Calcium	mg/L	433.3		
Dissolved Iron	mg/L	<0.05	0.3 (AO)	Acceptable
Dissolved Magnesium	mg/L	96.7		
Dissolved Manganese	mg/L	0.48		
Dissolved Potassium	mg/L	13.3		
Dissolved Sodium	mg/L	94.2	200 (AO)	Acceptable
Hardness (calculated, as CaCO3)	mg/L	1480		
Sodium Adsorption Ratio		1.07		
<b>Ammonia in water</b>				
Ammonia-N	mg/L	0.08		
Total Kjeldahl Nitrogen	mg/L	<2.00		
Total Phosphorus	mg/L	<0.040		

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

30

Unit# 288, 2880 45 Ave S.E.  
Calgary, AB, T2B 3M1  
Phone (403) 297-0868  
Fax: (403) 297-0869  
e-Mail: kaizenlab@kaizenlab.ca



**Notes:**

- Turbidity: Based on slow sand or diatomaceous earth filtration (1.0 NTU) / membrane filtration (0.1 NTU) / conventional treatment (0.3 NTU). No limits apply for well water not under the influence of surface water. For further details and additional guidance restriction, see Guidelines for Canadian Drinking Water Quality (GCDWQ 2019).

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

31



Unit# 288, 2880 45 Ave S.E.  
 Calgary, AB, T2B 3M1  
 Phone (403) 297-0868  
 Fax: (403) 297-0869  
 e-Mail: kaizenlab@kaizenlab.ca



KaizenLAB Sample #: 317767\_005 Sample ID: 03-02  
 Date Sampled: 12:03 27-Sep-2021

Parameter Description	Units	Result	Guideline Limits*	Comment
<b>Routine Water Potability Analysis (Potability pkg #2)</b>				
Electrical Conductivity (EC)	uS/cm	1070		
pH		7.5	7.0-10.5 (AO)	Acceptable
Total Dissolved Solids (calculated)	mg/L	626	500 (AO)	Unacceptable
True Colour	TCU	14	15 (AO)	Acceptable**
Turbidity	NTU	1.73	0.1/0.3/1.0 <sup>see notes</sup>	See notes
<b>Alkalinity Parameters of Water</b>				
Alkalinity (phenolphthalein, as CaCO3)	mg/L	<2.0		
Alkalinity (total, as CaCO3)	mg/L	588.7		
Bicarbonate (as HCO3)	mg/L	717.8		
Carbonate (as CO3)	mg/L	<1.5		
Hydroxide (as OH)	mg/L	<0.5		
<b>Anions in Water by IC</b>				
Bromide	mg/L	0.14		
Chloride	mg/L	2.74	250 (AO)	Acceptable
Fluoride	mg/L	0.22	1.5 (MAC)	Pass
Nitrate-N	mg/L	<0.010	10 (MAC)	Pass
Nitrite-N	mg/L	<0.005	1 (MAC)	Pass
Nitrite-N + Nitrate-N	mg/L	<0.015		
Phosphate	mg/L	<0.10		
Sulphate	mg/L	42.97	500 (AO)	Acceptable
<b>Cations in Water by ICP-OES</b>				
Dissolved Calcium	mg/L	163.1		
Dissolved Iron	mg/L	<0.05	0.3 (AO)	Acceptable
Dissolved Magnesium	mg/L	37.9		
Dissolved Manganese	mg/L	2.57		
Dissolved Potassium	mg/L	1.8		
Dissolved Sodium	mg/L	17.8	200 (AO)	Acceptable
Hardness (calculated, as CaCO3)	mg/L	583.5		
Sodium Adsorption Ratio		0.33		
<b>Ammonia in water</b>				
Ammonia-N	mg/L	0.09		
Total Kjeldahl Nitrogen	mg/L	<2.00		
Total Phosphorus	mg/L	<0.040		

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

32

Unit# 288, 2880 45 Ave S.E.  
Calgary, AB, T2B 3M1  
Phone (403) 297-0868  
Fax: (403) 297-0869  
e-Mail: kaizenlab@kaizenlab.ca



**Notes:**

- Turbidity: Based on slow sand or diatomaceous earth filtration (1.0 NTU) / membrane filtration (0.1 NTU) / conventional treatment (0.3 NTU). No limits apply for well water not under the influence of surface water. For further details and additional guidance restriction, see Guidelines for Canadian Drinking Water Quality (GCDWQ 2019).

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

33

Unit# 288, 2880 45 Ave S.E.  
 Calgary, AB, T2B 3M1  
 Phone (403) 297-0868  
 Fax: (403) 297-0869  
 e-Mail: kaizenlab@kaizenlab.ca



KaizenLAB Sample #: 317767\_006 Sample ID: TH08-03  
 Date Sampled: 11:51 27-Sep-2021

Parameter Description	Units	Result	Guideline Limits*	Comment
<b>Routine Water Potability Analysis (Potability pkg #2)</b>				
Electrical Conductivity (EC)	uS/cm	1080		
pH		7.8	7.0-10.5 (AO)	Acceptable
Total Dissolved Solids (calculated)	mg/L	689	500 (AO)	Unacceptable
True Colour	TCU	12	15 (AO)	Acceptable
Turbidity	NTU	6.84	0.1/0.3/1.0 <sup>see notes</sup>	See notes
<b>Alkalinity Parameters of Water</b>				
Alkalinity (phenolphthalein, as CaCO3)	mg/L	<2.0		
Alkalinity (total, as CaCO3)	mg/L	467.5		
Bicarbonate (as HCO3)	mg/L	570.0		
Carbonate (as CO3)	mg/L	<1.5		
Hydroxide (as OH)	mg/L	<0.5		
<b>Anions in Water by IC</b>				
Bromide	mg/L	<0.10		
Chloride	mg/L	0.65	250 (AO)	Acceptable
Fluoride	mg/L	0.43	1.5 (MAC)	Pass
Nitrate-N	mg/L	0.288	10 (MAC)	Pass
Nitrite-N	mg/L	<0.005	1 (MAC)	Pass
Nitrite-N + Nitrate-N	mg/L	0.288		
Phosphate	mg/L	<0.10		
Sulphate	mg/L	178.4	500 (AO)	Acceptable
<b>Cations in Water by ICP-OES</b>				
Dissolved Calcium	mg/L	144.6		
Dissolved Iron	mg/L	<0.05	0.3 (AO)	Acceptable
Dissolved Magnesium	mg/L	54.6		
Dissolved Manganese	mg/L	<0.05		
Dissolved Potassium	mg/L	4.7		
Dissolved Sodium	mg/L	18.9	200 (AO)	Acceptable
Hardness (calculated, as CaCO3)	mg/L	585.8		
Sodium Adsorption Ratio		0.34		
<b>Ammonia in water</b>				
Ammonia-N	mg/L	<0.05		
Total Kjeldahl Nitrogen	mg/L	<2.00		
Total Phosphorus	mg/L	0.064		

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

34

Unit# 288, 2880 45 Ave S.E.  
Calgary, AB, T2B 3M1  
Phone (403) 297-0868  
Fax: (403) 297-0869  
e-Mail: kaizenlab@kaizenlab.ca



**Notes:**

- Turbidity: Based on slow sand or diatomaceous earth filtration (1.0 NTU) / membrane filtration (0.1 NTU) / conventional treatment (0.3 NTU). No limits apply for well water not under the influence of surface water. For further details and additional guidance restriction, see Guidelines for Canadian Drinking Water Quality (GCDWQ 2019).

35

Unit# 288, 2880 45 Ave S.E.  
 Calgary, AB, T2B 3M1  
 Phone (403) 297-0868  
 Fax: (403) 297-0869  
 e-Mail: kaizenlab@kaizenlab.ca



KaizenLAB Sample #: 317767\_007 Sample ID: 02-02  
 Date Sampled: 12:37 27-Sep-2021

Parameter Description	Units	Result	Guideline Limits*	Comment
<b>Routine Water Potability Analysis (Potability pkg #2)</b>				
Electrical Conductivity (EC)	uS/cm	1360		
pH		7.4	7.0-10.5 (AO)	Acceptable
Total Dissolved Solids (calculated)	mg/L	891	500 (AO)	Unacceptable
True Colour	TCU	<4	15 (AO)	Acceptable
Turbidity	NTU	6.12	0.1/0.3/1.0 <sup>see notes</sup>	See notes
<b>Alkalinity Parameters of Water</b>				
Alkalinity (phenolphthalein, as CaCO3)	mg/L	<2.0		
Alkalinity (total, as CaCO3)	mg/L	569.7		
Bicarbonate (as HCO3)	mg/L	694.6		
Carbonate (as CO3)	mg/L	<1.5		
Hydroxide (as OH)	mg/L	<0.5		
<b>Anions in Water by IC</b>				
Bromide	mg/L	0.15		
Chloride	mg/L	31.27	250 (AO)	Acceptable
Fluoride	mg/L	0.19	1.5 (MAC)	Pass
Nitrate-N	mg/L	<0.010	10 (MAC)	Pass
Nitrite-N	mg/L	<0.005	1 (MAC)	Pass
Nitrite-N + Nitrate-N	mg/L	<0.015		
Phosphate	mg/L	<0.10		
Sulphate	mg/L	200.5	500 (AO)	Acceptable
<b>Cations in Water by ICP-OES</b>				
Dissolved Calcium	mg/L	265.6		
Dissolved Iron	mg/L	<0.05	0.3 (AO)	Acceptable
Dissolved Magnesium	mg/L	35.1		
Dissolved Manganese	mg/L	2.23		
Dissolved Potassium	mg/L	1.9		
Dissolved Sodium	mg/L	9.2	200 (AO)	Acceptable
Hardness (calculated, as CaCO3)	mg/L	808.0		
Sodium Adsorption Ratio		0.14		
<b>Ammonia in water</b>				
Ammonia-N	mg/L	0.06		
Total Kjeldahl Nitrogen	mg/L	<2.00		
Total Phosphorus	mg/L	0.135		

\*CDWQG = Canadian Drinking Water Quality Guidelines, Health Canada 2020; MAC = Maximum Acceptable Concentration (affects health), AO = Aesthetic Objective (does not affect health but affects color, taste, etc.), OG = Operational Guidance

36

**Notes:**

- Turbidity: Based on slow sand or diatomaceous earth filtration (1.0 NTU) / membrane filtration (0.1 NTU) / conventional treatment (0.3 NTU). No limits apply for well water not under the influence of surface water. For further details and additional guidance restriction, see Guidelines for Canadian Drinking Water Quality (GCDWQ 2019).

**Test Methodologies**

---

- Alkalinity in Water: Modified from SM 2320B
- Ammonia in Water: Modified from SM 4500-NH3 F
- Anions in Water: Modified from SM 4110B
- Cations in Water: Modified from SM 3030B and SM 3120B
- Electrical Conductivity in Water: Modified from SM 2510B
- pH of Water: Modified from SM 4500-H+ B
- Total Dissolved Solids (calculated): Modified from SM 1030E
- Total Kjeldahl Nitrogen in Water: Modified from SM 4500-N(org) B and D
- Total Metals in Water: Modified from EPA 200.2 and SM 3120B
- True Colour in Water: Modified from SM 2120 C
- Turbidity in Water: Modified from SM 2130B

Final Review by:



Shawnl Turner  
Client Services Representative

Note: The results in this report relate only to the items tested and as received. Information is available for any items in 7.8.2.1 of ISO/IEC 17025:2017 that cannot be put on a test report. The report shall not be reproduced except in full without written approval of KaizenLAB. The validity of results may be affected if the information is provided by the customer.

Pass/Acceptable: The measurement result conforms with the specification limit when the measurement uncertainty is taken into account.  
Pass/Acceptable<sup>™</sup>: It is not possible to state conformance using a 95 % coverage probability for the expanded uncertainty although the measurement result is below the limit.  
Fail/Unacceptable: The measurement result does not conform with the specification limit when the measurement uncertainty is taken into account.

The statement of conformity is based on a 95% coverage probability for the expanded uncertainty. The test results and the statement of conformance with specification in this report relate only to the test sample as analysed/tested and not to the sample/item from which the test sample was drawn.

**debbie@onoway.ca**

---

**From:** Bridgitte Coninx <bconinx@onoway.ca>  
**Sent:** February 3, 2022 12:11 PM  
**To:** Debbie Giroux; Len Kwasny; Robert Winterford; Robin Murray; Lisa Johnson  
**Subject:** Fwd: Register today for February's Corporate Planning and Finance Course

Looks to be of fantastic value to us.

Sent from my iPad

Begin forwarded message:

**From:** "Exec. Assistant on behalf of Dan Rude" <EA\_DRude@abmunis.ca>  
**Date:** February 3, 2022 at 8:43:05 AM MST  
**To:** Bridgitte Coninx <bconinx@onoway.ca>  
**Subject:** Register today for February's Corporate Planning and Finance Course

Hello Mayors, Councillors and CAOs,

Recognizing that budgeting is one of the most challenging aspects of municipal government, the [Elected Officials Education Program \(EOEP\)](#) is following on our Munis 101 course with a virtual offering of [Corporate Planning and Finance](#).

[Register](#) for the course which will be held on Zoom over four evening sessions.

- Wednesday, February 16, from 6:30 to 8:30 p.m.
- Wednesday, February 23, from 6:30 to 8:30 p.m.
- Wednesday, March 2, from 6:30 to 8:30 p.m.
- Wednesday, March 9, from 6:30 to 8:30 p.m.

The course is taught by Rodney Boyko, a municipal finance expert with experience as a Chief Financial Officer. Rodney will guide participants through the role of elected officials in municipal financial planning, budgeting and monitoring, and how this differs from the role of administration. It will also help participants understand how the public financial processes differ from those you might be used to from the private sector.

Don't miss out on this opportunity to learn about the essentials of municipal finance and work towards your Municipal Elected Leaders Certificate (MELC).

EOEP's registrar is hard at work scheduling classes for the rest of the year, to ensure each course in our roster is offered at least once. Stay tuned for a full course schedule.

**Dan Rude** | Chief Executive Officer

**ALBERTA URBAN MUNICIPALITIES ASSOCIATION**

---

D: 780.431.4535 | C: 780.951.3344 | E: [drude@auma.ca](mailto:drude@auma.ca)

300-8616 51 Ave Edmonton, AB T6E 6E6

Toll-Free: 310-MUNI | 877-421-6644 | [www.abmunis.ca](http://www.abmunis.ca)



---

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the sender. This message contains confidential information and is intended only for the individual named. If you are not the named addressee, you should not disseminate, distribute or copy this email.

39



# Municipal Corporate Planning and Finance

Understanding municipal finances is fundamental to the job of an elected official. Municipal councils are expected to plan, govern and set policy for the best interests of their community. Sound financial planning and management is key to supporting a healthy municipality that can ensure that its current and future service commitments are funded in a sustainable manner.

It is important that elected officials understand how financial planning and monitoring align with the municipality's business cycle, including strategic planning, business planning and performance measurement. Elected officials need to understand their role in establishing and prioritizing competing service level demands on behalf of citizens and then determine strategies to fund those service level commitments.

## *Module 1: Setting the Strategic Context*

After completing this module, participants will be able to:

- Understand what the elected official's role is in the strategic planning process, citizen participation and risk management

## *Module 2: Financial Planning Overview*

After completing this module, participants will be able to:

- Understand service levels and performance measures
- Feel comfortable with the annual budget process
- Ask good questions regarding their operating budget and capital planning
- Identify the contents of a capital budget and understand multi-year financial and capital plans

## *Module 3: Revenue and Funding*

After completing this module, participants will be able to:

- Understand property tax
- Identify debt versus reserves
- Have an understanding about debt servicing, grants and transfers

### Upcoming Courses

Municipal Corporate Planning and Finance - Feb 16

Council's Role in Service Delivery - Mar 13 - Mar

Council's Role in Strategic Planning - Mar 13 - Mar

[all courses](#)

## Module 4: Monitoring and Evaluation

After completing this module, participants will be able to:

- Identify the segregation of duties
- Understand cashflow and investments
- Understand accounting systems, records and internal controls
- Read financial statements

### **ABOUT**

**About EOEP**

**Municipal Elected Leaders Certificate**

**MGA Requirements**

**FAQ**

**Privacy Policy**

**Legal Notice**

### **Courses**

**Course Descriptions**

**Additional Materials**

### **Contact Us**

**Phone: 780-989-7431**

**Email: registrar@eoep.ca**

[About](#)

[Courses](#)

[Contact Us](#)



Designed by **Elegant Themes**