



Town of Onoway

Box 540, Onoway, AB T0E 1V0

Request for Quote **Onoway Hydrant and Valve Replacement** **2022**

Quote for Hydrant and Valve Replacement

- Supply and install of 1 fire hydrant and isolation valve
- Supply and install of 5 main valves (150mm)
- Supply all equipment, labour, materials and traffic control to complete the work
- Complete all the restoration of asphalt, concrete and or grass

Hydrant and Valve specs:

- McAvity Brigadier Fire Hydrant
- Clow AWWA valves

Excavation and Restoration

- Excavation shall be limited to 3m x 3m for main valves and 3m x 5m for hydrant and isolation valve.
- Backfilling shall be done in lifts not to exceed 300mm compacted.
- Road restoration shall have a minimum of 300mm of 20mm GBC and 100mm of hot mix asphalt.
- Grass shall be restored with 75mm of top soil and seeded.
- Water supply shall be maintained to all residents and businesses impacted.
- Bacti Samples shall be taken and results provided prior to putting back in service.

Contractor shall supply

- All equipment, tools, materials, traffic control to complete the work.
- Hydro Vac if required (must be included in price)
- A traffic safety plan
- Trained personnel
- Proof of WCB and Liability insurance
- All barricades, signage, traffic control devices and personal protective equipment (PPE).
- Trained flag person(s)

It is the responsibility of the contractor to verify actual depths, dimensions and isolation points.
Actual areas to be done will be dependant upon budget. Some items may be removed or added based on the budget.

For more information or to schedule an appointment for review, please contact Jason Madge at 780-967-5338 or via email at jason@onoway.ca

The project must be completed prior to August 31, 2022

Submissions must include a minimum of three references for same or similar work for a municipality in the last 5 years.

Quotes to be submitted by 1200hrs (noon) MST on Friday April 1, 2022

Town of Onoway
4812 – 51 Street
Box 540
Onoway, AB T0E 1V0
Email: jason@onoway.ca
Fax: 780-967-0685

Hydrant and Valve Replacement List

Hydrant and isolation valve at the corner of 50st and 48ave
Valve (2) replacement at the intersection of 50st and 48ave
Valve (1) replacement at the corner of 51st and 48ave
Valve (2) replacement on 47a ave